

Issued in accordance with British Standard 7671 - Requirements for Electrical Installations

ISSUED IN ACCORDANCE WITH BRITISH STANDARD 7671 - REQUIREMENTS FOR ELECTRICAL INSTALLATIONS

Client: **Comfrey House. PTH Company**

Address: **42, Seacroft Crescent
Sunderland.**

Postcode: **SN1 4GW**

Extent of the electrical installation covered by this report:
Power and lighting circuits

Agreed limitations including the reasons, if any, on the inspection and testing:
N/A

Agreed with:
N/A

Operational limitations including the reasons (see page No. **N/A**)
N/A

The inspection and testing have been carried out in accordance with BS 7671, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected.

Purpose for which this report is required:
Electrical Certification on electrical circuits for handover

Date(s) on which inspection and testing were carried out:

Occupier: **Multiple Occupancies**

Address: **42, Seacroft Crescent
Sunderland.**

Postcode: **SN1 4GW**

Estimated age of the electrical installation: **10** years

Date of previous inspection: **N/A**

Records of installation available: **N/A**

Evidence of alterations or additions: **N/A**

Electrical Installation Certificate No or previous Periodic Inspection or Condition Report No: **N/A**

Records held by: **N/A**

General condition of the installation (in terms of electrical safety):
Good

Summary of the condition of the installation continued on additional pages? No Yes Specify page No(s):

Overall assessment of the installation: **SATISFACTORY** ~~UNSATISFACTORY~~ (Delete as appropriate)

An 'Unsatisfactory' assessment indicates that dangerous and/or potentially dangerous conditions have been identified

PROCESSED ELECTRICAL INSTALLATION REPORT FOR A COMPETENT PERSON

Referring to the attached schedules of inspection and test results, and subject to the limitations at D:

There are no items adversely affecting electrical safety or The following observations and recommendations for action are made

Item No Observations

1

Further investigation required (Y or ✓)
Classification code †

I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described on page 1 (see C), having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations (see F) and the attached schedules (see H), provides an accurate assessment of the condition of the electrical installation taking into account the stated extent of the installation and the limitations on the inspection and testing (see D).

I/We further declare that in my/our judgement, the said installation was overall in **SATISFACTORY** condition.

condition (see F) at the time the inspection was carried out, and that it should be further inspected as recommended (see I).

*Delete as appropriate

INSPECTION, TESTING AND ASSESSMENT BY:

Signature: *W. Williams*
Name: (CAPITALS) **WAYNE WILKINS**
Position: **Supervisor**
Date:

REPORT REVIEWED AND CONFIRMED BY: †

Signature: *W. Williams*
Name: (CAPITALS) **WAYNE WILKINS**
Date: **7th March 2020**

Schedule of Inspections: Page(s) No 4, 5, 6

Additional pages, including data sheets for additional source(s): **N/A** Page No(s)

Schedule of Circuit Details for the Installation: Page No(s) **7**

Schedule of Test Results for the Installation: Page No(s) **7**

The pages identified are an essential part of this report. The report is valid only if accompanied by all the schedules and additional pages identified above.

Immediate remedial action required for items:
Urgent remedial action required for items:
Further investigation required for items:
Improvement recommended for items:

Additional pages? No Yes Specify page No(s):
† One of the following codes, as appropriate, has been allocated to each of the observations made above to indicate to the person(s) responsible for the installation the degree of urgency for remedial action:
Code C1 'Danger present'. Risk of injury. Immediate remedial action required.
Code C2 'Potentially dangerous'. Urgent remedial action required.
Code C3 'Improvement recommended'.
Please see the reverse of this page for guidance regarding the Classification codes.

† The completed report should preferably be reviewed by another competent person to confirm that the declared overall condition of the electrical installation is consistent with the inspection and test results, and with the observations and recommendations for action (if any) made in the report

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT FOR A SINGLE CIRCUIT

J. DETAILS OF THE ELECTRICAL CONTRACTOR

Trading title: **Universal Electrical**
 Address: **15, Falmouth Grove Swindon Wiltshire SN3 1BX**
 Telephone number: **07792761471**
 Email address: **Universal@yohoc.co.uk**

I. NEXT INSPECTION

We recommend that this installation is further inspected and tested after an interval of not more than:

245 (Enter interval in terms of years or months, as appropriate)
 provided that any items at F which have been attributed a Classification code C1 (danger present) are remedied immediately and that any items which have been attributed a code C2 (potentially dangerous) or require further investigation are remedied or investigated respectively as a matter of urgency. Items which have been attributed a Classification code C3 should be improved as soon as practicable (see F).

K. SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System type(s)	Number and type of live conductors	Other (please state)	Nature of supply parameters	Characteristics of primary supply overcurrent protective device(s)
TNS	a.c. ✓		Nominal voltage(s) U_0 : 230 V	BS(EN) 1361
TNCS	1-phase (2-wire) ✓		Nominal frequency, f_{nom} : 50 Hz	Type II
TT	2-phase (3-wire) ✓		Prospective fault current, $I_{pf}^{(max)}$: 1-36 kA	Rated current 100 A
	3-phase (3-wire)		External earth fault loop impedance, $Z_e^{(ext)}$: 0.17 Ω	Short-circuit capacity kA
			Notes: (1) by enquiry (2) by measurement (3) where more than one source, record the higher or highest value (4) by measurement	Confirmation of supply polarity ✓ (✓)

L. PARTICULARS OF INSTALLATION AT THE ORIGIN

Means of earthing		Details of installation earth electrode (where applicable)	
Distributor's facility:	Type: (e.g. rod(s), tapes etc)	Location:	
Installation earth electrode:	Electrode resistance, R_A :	Method of measurement:	
—	—	n/a	n/a
n/a	n/a (Ω)	n/a	n/a
Earthing and protective bonding conductors			
Main switch or circuit-breaker		Main protective bonding conductors	
Type BS(EN)	Voltage rating	Conductor material	Conductor csa
No. of poles	Rated current, I_n	Copper	16 mm ²
Primary supply conductors (material)	RCD operating current, $I_{\Delta n}$	Conductor csa	16 mm ²
Primary supply conductors (c-sa)	Rated time delay	Connection/continuity verified	✓
	RCD operating time (at $I_{\Delta n}$)	Connection/continuity verified	✓
		Connection/continuity verified	✓
Bonding of extraneous-conductive-parts (✓)		Bonding of extraneous-conductive-parts (✓)	
Water service	✓	Water service	✓
Oil service	n/a	Oil service	n/a
Lightning protection	n/a	Lightning protection	n/a
Gas service	✓	Gas service	✓
Structural steel	n/a	Structural steel	n/a
Other incoming service(s)	n/a	Other incoming service(s)	n/a

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Original (To the person ordering the work)

SCHEDULE OF INSPECTIONS

Item Description	Outcome*	Location reference	Item Description	Outcome*	Location reference
1.0 Condition/adequacy of distributor's/supply intake equipment	✓		4.0 Consumer unit(s)	✓	
1.1 Service cable	✓		4.1 Adequacy of working space or access to consumer unit	✓	
1.2 Service cut-out/fuse(s)	✓		4.2 Security of fixing	✓	
1.3 Meter tails - distributor	✓		4.3 Condition of enclosure(s) in terms of IP rating	✓	
1.4 Meter tails - consumer	✓		4.4 Condition of enclosure(s) in terms of fire rating	✓	
1.5 Metering equipment	✓		4.5 Enclosure not damaged/deteriorated so as to impair safety	✓	
1.6 Means of main isolation (where present)	✓		4.6 Presence of linked main switch	✓	
2.0 Presence of adequate arrangements for other sources (microgenerators etc)			4.7 Operation of main switch (functional check)	✓	
3.0 Earthing and bonding arrangements			4.8 Manual operation of circuit-breakers and RCDs to prove disconnection	✓	
3.1 Presence and condition of distributor's earthing arrangement	✓		4.9 Correct identification of circuits and protective devices	✓	
3.2 Presence and condition of earth electrode connection	N/A		4.10 Presence of RCD test notice at or near consumer unit	✓	
3.3 Confirmation of adequate earthing conductor size	✓		4.11 Presence of non-standard (mixed) cable colour warning notice at or near consumer unit	N/A	
3.4 Accessibility and condition of earthing conductor at Main Earthing Terminal (MET)	✓		4.12 Presence of alternative supply warning notice at or near consumer unit	N/A	
3.5 Confirmation of adequate main protective bonding conductor sizes	✓		4.13 Presence of replacement next inspection recommendation label	N/A	
3.6 Condition and accessibility of main protective bonding conductor connections	✓		4.14 Presence of other required labelling (please specify)	✓	
3.7 Provision of earthing and bonding labels at all appropriate locations	✓		4.15 Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)	✓	
			4.16 Single-pole protective devices in the line conductor only	✓	

* All boxes must be completed.
 ✓ indicates Acceptable condition
 'N/A' indicates a limitation

'/A' indicates Not applicable
 Unacceptable condition state C1 or C2
 Improvement recommendation state C3

Further investigation required state F1
 (to determine whether danger or potential danger exists)

Outcome
 Provide additional comment where appropriate on attached numbered sheets.
 C1, C2 and C3 coded items to be recorded in section F of the report.

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT

SCHEDULE OF INSPECTIONS

Item Description	Outcome*	Location reference	Item Description	Outcome*	Location reference
4.17 Protection against mechanical damage where cables enter metallic consumer unit	✓		5.11 Concealed cables incorporating earthed armour or sheath, or run within earthed wiring containment system, or otherwise protected against mechanical damage from nails, screws and the like where not in prescribed zones or not protected by 30 mA RCD (see extent and limitations)	✓	
4.18 Protection against electromagnetic effects where cables enter metallic consumer unit/enclosure	✓		5.12 Provision of additional protection by RCD not exceeding 30 mA		
4.19 RCDs provided for fault protection -- includes RCBOs	✓		<ul style="list-style-type: none"> used to supply mobile equipment not exceeding 32 A rating for use outdoors 	✓/N/A	
4.20 RCDs provided for additional protection -- includes RCBOs	✓		<ul style="list-style-type: none"> for all socket-outlets not exceeding 20 A rating unless exempt for cables concealed in walls or partitions 	✓	
5.0 Final circuits	✓		5.13 Provision of fire barriers, sealing arrangements and protection against thermal effects	✓	
5.1 Identification of conductors	✓		5.14 Band II cables segregated/separated from Band I cables	✓	
5.2 Cables correctly supported throughout their run	✓		5.15 Cables segregated/separated from communications cabling	✓	
5.3 Condition of insulation of live parts	✓		5.16 Cables segregated/separated from non-electrical services	✓	
5.4 Non-sheathed cables protected by enclosure in conduit, ducting or trunking (including confirmation of the integrity of conduit and trunking systems)	✓		5.17 Termination of cables at enclosures (extent of sampling indicated in Section D of the report)		
5.5 Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	✓		<ul style="list-style-type: none"> Connections soundly made and under no undue strain No basic insulation of a conductor visible outside enclosures Connections of live conductors adequately enclosed Adequately connected at point of entry to enclosure (glands, bushes etc.) 	✓	
5.6 Adequacy of protective devices; type and rated current for fault protection	✓				
5.7 Presence and adequacy of circuit protective conductors	✓				
5.8 Co-ordination between conductors and overload protective devices	✓				
5.9 Wiring system(s) appropriate for the type and nature of the installation and external influences	✓				
5.10 Concealed cables installed in prescribed zones (see extent and limitations)	✓				

* All boxes must be completed.
 ✓ indicates Acceptable condition
 N/A indicates Not applicable
 ✗ indicates Unacceptable condition state C1 or C2
 Improvement recommended state C3
 Further investigation required state F1 (to determine whether danger or potential danger exists)
 Outcome
 Provide additional comment where appropriate on attached numbered sheets.
 C1, C2 and C3 coded items to be recorded in section F of the report.